



Oneonta Block Company

607-432-6641

Web www.oneontablock.com

Email obc@oneontablock.com

Pickett Building Materials

607-432-8391

Web www.pickettbuildingmaterials.com

Email pbm@pickettbuildingmaterials.com

6459 State Highway 23, Oneonta, NY 13820

Fax 607-433-6284 • Toll Free in NYS 800-686-0111

Divisions of Arnan Development Corporation

DATE: 7/26/2011

MASON MANUFACTURER: Oneonta Block Company, Oneonta, NY

CERTIFICATE OF COMPLIANCE

6" Concrete Masonry Units ASTM C90

THIS WILL CERTIFY THAT: CONCRETE MASONRY UNITS, MANUFACTURED BY ONEONTA BLOCK COMPANY FOR THE ABOVE NAMED PROJECT, COMPLY WITH THE FOLLOWING SPECIFICATIONS:

ASTM C140 Test from the National Concrete Masonry Association Demonstrating Compliance to ASTM C90 'Standard Specification for Load Bearing Concrete Masonry Units.' With a minimum 28 day area compressive strength of 2800 psi.

ASTM C1314 Standard test method for compressive strength of masonry prisms showing the 28-day prism test values of the 2800 net area compressive strength units.

ASTM C426 Standard test method for linear drying shrinkage of concrete masonry units. Demonstrating compliance to ASTM C90 'Standard Specification for Load Bearing Concrete Masonry Units.

Oneonta Block Company will exceed a 28-day net area compressive strength of 3500 psi.

ALL REGULAR WEIGHT BLOCK ARE MANUFACTURED WITH NEW YORK STATE DOT CERTIFIED LIMESTONE AND NEW YORK STATE DOT CERTIFIED GLENS FALLS PORTLAND CEMENT TYPE III.

**Block manufactured by Oneonta Block Company are
High Strength and meet F'2000**